

VOC Content Test Certificate

Monday 14th August 2023

Supplier: Lincoln Sentry Group Pty Ltd (5/243 Bradman Street, Acacia Ridge, QLD, 4110, Australia).

Sample Description: Hexfix Gap Filler White

Date Tested: July 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Hexfix Gap Filler White
General Purpose Adhesives and Sealants Limit: 50 grams per litre	2 grams per Litre as VOC content per material
Meets GBCA VOC Content Requirement	Yes



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue date: 14/8/2023

Expiry date: 31/7/2027

P23060119