

# VOC Content Test Certificate

Monday 14<sup>th</sup> August 2023

Supplier: Lincoln Sentry Group Pty Ltd (5/243 Bradman Street, Acacia Ridge, QLD, 4110, Australia).

Sample Description: Hexfix TR-68

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC)  
Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as  
South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Hexfix TR-68</b>
<b>General Adhesives and Sealants limit: ≤50 grams per litre</b>	<b>31 grams per Litre as VOC content per material</b>
<b><i>We hereby certify Hexfix TR-68 product is below the VOC Content limits of chosen categories specified by Green Building Council of Australia, Green Star Design &amp; As Built, and Green Star Interiors</i></b>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Issue date: 14/08/2023

Expiry date: 30/09/2026

P23060119