

# VOC Content Test Certificate

Monday 14<sup>th</sup> August 2023

Supplier: Lincoln Sentry Group Pty Ltd (5/243 Bradman Street, Acacia Ridge, QLD, 4110, Australia).

Product Name: Hexfix PU

Date Tested: 8<sup>th</sup> August 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Hexfix PU</b>
<b>General Purpose Adhesives and Sealants:</b> <b>50 grams per litre</b>	<b>28 grams per litre as VOC content per material</b>
<i>We hereby certify Hexfix PU is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant